



# Certificate of Compliance

## Fiber Reinforced Composite Pipe and Fittings

The following items are FM Approved when manufactured at the plant listed below:

Description	Size (inch)	Pressure Rating bar (psi)
Series 6000 Quick-Lock	2 to 24	12 (175)
Series 2414FM	2 to 24	14 (200)
Series 2416FM	2 to 24	16 (230)
Series 2420FM	2 to 24	20 (290)

The *Approval Guide*, a publication of FM Approvals, and the Approval Reports listed below should be consulted for specific products, sizes and limitations.

Manufactured by:

Ameron (Pte.) Ltd.  
7A Tuas Av 3  
Singapore 2263  
Singapore

FM Approvals confirms that the items have been found to comply with the following standard:


FM Approvals Standard 1614


Project Identifiers: 1W9A4.AH  
3010909  
3014773  
3020745

Date of Approval: Jan. 26, 1996  
Date of Approval: Dec. 7, 2001  
Date of Approval: Dec. 23, 2002  
Date of Approval: Sept. 22, 2004



Member of the FM Global Group

  
Richard B. Dunne, Manager, Hydraulics Group

  
Date