

Certificate of Compliance

Certificate Number **290307-MH30132**
Report Reference **02012007, 18012007, 04012007**
Issue Date **2007 March 29**

Page 1 of 1



**Underwriters
Laboratories Inc.®**

Issued to:

Smith Fibercast

2700 W 65th St
Little Rock, AR 72209
United States

*This is to certify that
representative samples of*

Pipes and Related Products

Green thread molded fittings (D) Red thread II spray up fittings (E)
Red thread II molded fittings (D) Red thread II wound fittings (D)
Green thread spray up fittings (E) Green thread wound fittings (D)

*Have been investigated by Underwriters Laboratories Inc.® in
accordance with the Standard(s) indicated on this Certificate.*


Standard(s) for Safety:

ANSI/NSF STANDARD 61 - Drinking Water System Components - Health Effects

Additional Information:

Water Contact Temperature: 23 deg. C
(D) = Classified for sizes ≥ 1 in.
(E) = Classified for sizes ≥ 8 in.

Only those products bearing the UL Classification Mark should be considered as being covered by UL's Classification and Follow-Up Service.

The UL Classification Mark includes: UL in a circle symbol:  with the word "CLASSIFIED" (as shown); a control number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of the product; and, the product category name (product identity) as indicated in the appropriate UL Directory.

Look for the UL Classification Mark on the product

Issued by:

Nancy J. Batey, Project Handler II

Underwriters Laboratories Inc.

Reviewed by:

Douglas Frederick, Senior Project Chemist

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL.
For questions in The United States of America you may call 1-877-UL-HELPS.